

PCC Confined Space Index June 2015
Swan Island Training Center

The following table provides index and initial space classification for spaces at Swan Island Center. The numbers noted are related to notation on maps.

Map Location #	Building/Location	Space Type or Name	Initial Classification
100	Outside STC Corner of Cutter and Leverman Streets	Double Hatch Quest Communication Vault with wiring system relatively shallow at about 2 feet	Due to the depth a person cannot fully enter. Too shallow to enter as a confined space
101	Vault near gas pumps	Single hatch, deep, full of water, some conduit at bottom of the vault	Permit
102	Vault in North Parking Lot at sign Row 8 Row 7	No ladder, water in access to water line and valve/meter	Alternate Entry Permit if water is pumped out
103	Raise Water Vault off sidewalk near Cutter and Leverman Streets	Vault appears 8 feet by 6 feet, no sure on depth but generally these are 6 to 8 feet deep	Alternate Entry Permit
NOT CONFINED SPACE			
104	Water Meter by Cutter Circle Street	Single hatch to water meter that is less than few inches deep	Too shallow to enter