

**PCC Confined Space Index March 31, 2014 rev. February 18, 2015
Metro Center**

The following table provides index and initial space classification for spaces at Metro Center. The numbers noted are related to notation on maps.

Map Location #/ Responsible Group	Building/Location	Space Type or Name	Initial Classification
Vaults or Manhole Entrances: Outside locations		Outside single, double and Round manhole covers that for sewer or stormwater manholes	Permit or in some cases for vaults may be Alternate Entry
101/PCC FMS	Parking Lot	Stormwater Management system vault – TO SHALLOW TO ENTER	NOT A CONFINED SPACE
102/PCC FMS or Outside Contractor	Sidewalk on 42nd Street North end of the campus parking lot	Potable Water Vault for Fire and Drinking Water valves and backflow assembly	Alternate/Permit confined space
103/PCC FMS or Outside Contractor	Sidewalk on Killingsworth Street North at main entrance – west side of the driveway	Vault hatch cover – water meter, less than 1 foot deep – TO SHALLOW TO ENTER	NOT A CONFINED SPACE
104/PCC FMS or Outside Contractor	Sidewalk on Killingsworth Street North at main entrance – east side of the driveway	Vault hatch cover –Water meter piping. TO SHALLOW TO ENTER	NOT A CONFINED SPACE
200 HVAC			
201/PCC FMS	HVAC plenum/filter housing	Roof units	NOT A CONFINED SPACE WITH LOCKOUT
Notes	Boilers do not have access to the small units interior. There is no direct access into building HVAC ductwork		
300 Tanks	NONE		