

**PCC Confined Space Index Updated March 31, 2014 rev. June 9, 2015
Newberg Center**

The following table provides index and initial space classification for spaces at Newberg Center. The numbers noted are related to notation on maps.

Map Location #/ Responsible Group	Building/Location	Space Type or Name	Initial Classification
N101/PCC FMS	Vault corner of Brutshcer and Werth Blvd. near N102	Water vault with large water supply pipe and valve. Standing water, at least 8 feet deep with a stationary ladder for access.	Permit /Alternate Entry
N102/PGE	Corner of Brutshcer and Werth Blvd.	PGE Electric vault at least 5 feet deep with electrical cables	Permit/Electrical Standard Enclosed Space
N103	Triple lid vault after the circle turn around before the service drive that goes behind the building	Electrical Vault	Permit Required
N104	Vault on the sidewalk on Brutscher street at the edge of the property.	Checking – to be determine	Until evaluated the space is considered Permit Entry
No stormwater manhole as bioswale control stormwater.			
Sewer manholes are responsibility of the local City of Newberg Environmental Services			
200 HVAC			
N201/PCC FMS	HVAC plenum/filter housing	The issues fall hazard which has been addressed with proper anchor points	Not confined spaces wit lockout and fall protection on HRV#1-3 filter access points
300 Tanks	None		