



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Swan Island Trade & Industries Center

Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	Outside Room 124	Drinking Fountain	9/2/2016	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document, entitled *3Ts for Reducing Lead in Drinking Water in Schools*. First draw samples were collected and laboratory analysis indicates that all water samples collected contained lead at concentrations below the EPA action level of 20 ppb.

ppb = parts per billion (20 ppb = 0.020 mg/L)