



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
AM	1	Outside Room 115A in Shop	Drinking Fountain	9/1/2016	1.2
AM	1	Outside Room 115A in Shop	Bottle Fill Station	9/1/2016	ND
AM	2	Between Rooms 210 & 216	Drinking Fountain	9/1/2016	ND
BK	G	Outside Elevator	Drinking Fountain (North)	9/1/2016	ND
BK	1	Between Restrooms	Drinking Fountain (West)	9/1/2016	ND
BK	2	Next to Elevator	Drinking Fountain (North)	9/1/2016	1.2
CC	1	Outside Room 102 ASPCC	Drinking Fountain	9/1/2016	1.0
CC	2	River City Café Near 1 st Aid Kit	Kitchen Sink (North)	9/1/2016	2.7
CSB	1	North Gender Neutral Restroom	Sink	9/1/2016	1.9
CSB	2	Outside Room 205	Drinking Fountain	9/1/2016	ND
CSB	2	Outside Room 205	Drinking Fountain w/ Gooseneck	9/1/2016	ND
CSB	3	Between Restrooms	Drinking Fountain (Tall)	9/1/2016	ND
CT	1	Outside Rooms 116 & 118	Drinking Fountain	9/1/2016	ND
CT	2	Room 216 Break Area	Sink	9/1/2016	ND
HT	G	PE/Weight Room West Wall	Drinking Fountain (North)	9/1/2016	1.8
HT	1	Outside Room 117/Elevator	Drinking Fountain (South)	9/1/2016	ND
HT	2	Child Dev Center Room 220	Kitchen Sink (South)	9/1/2016	4.3
HT	3	Outside Room 315	Drinking Fountain	9/1/2016	ND
HP	1	Break Room/Custodial	Drinking Fountain	9/1/2016	ND
HP	2	Gender Neutral Restroom	Sink	9/1/2016	2.2
LIB	1	Outside Room 135	Drinking Fountain	9/1/2016	ND
LIB	2	Room 208C	Kitchen Sink	9/1/2016	1.1
PAC	1	Main Lobby at West Entry	Drinking Fountain	9/1/2016	1.6
ST	2	Hall Between Rooms 206 & 212	Drinking Fountain	9/1/2016	ND
ST	3	Break Room Next to 313C	Sink	9/1/2016	5.4
SS	2	North of Room 201K	Drinking Fountain	9/1/2016	ND
SCB	1	Men’s Restroom Bunker	NE Sink	9/1/2016	ND
SCB	2	Men’s Restroom Bunker	SW Sink	9/1/2016	2.2
TCB	1	Kitchen Room 115C	Sink	9/1/2016	ND
TCB	2	Near Elevator	Drinking Fountain	9/1/2016	ND
TCB	3	Next to Restrooms	Drinking Fountain	9/1/2016	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document, entitled *3Ts for Reducing Lead in Drinking Water in Schools*. First draw samples were collected and laboratory analysis indicates that all water samples collected contained lead at concentrations below the EPA action level of 20 ppb.

ppb = parts per billion (20 ppb = 0.020 mg/L)