



Environmental Health & Safety
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus

| Building | Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|----------|-------|-----------------------------|---------------------------|-------------|-----------------------|-------------------|
| AM | 1 | Room 101 Maker Space | Refrigerator | 8/17/2017 | 0.094 | ND |
| AM | 2 | Room 206 | Bottle Fill Station | 8/17/2017 | 0.065 | 2.0 |
| BK | G | Gender Neutral Restroom | Sink | 8/17/2017 | 0.175 | 6.0 |
| BK | 1 | Room 107 Kitchenette | Sink | 8/17/2017 | 0.278 | ND |
| BK | 2 | Next to Elevator | Drinking Fountain (North) | 8/17/2017 | 0.754 | ND |
| CC | 1 | Room 116E Print Center | Sink | 8/17/2017 | 0.343 | ND |
| CC | 2 | Outside 271 | Drinking Fountain (tall) | 8/17/2017 | 0.161 | ND |
| CSB | 1 | Room 109 Kitchen Sink | Sink | 8/17/2017 | 0.308 | ND |
| CSB | 2 | Room 204 Kitchenette | Sink | 8/17/2017 | 0.211 | ND |
| CSB | 3 | Room 223 Restrooms | Sink | 8/17/2017 | 0.276 | ND |
| CT | 1 | Room 126 Child Development | Sink | 8/17/2017 | 0.078 | 11.0 |
| CT | 2 | Gender Neutral Restroom | Sink | 8/17/2017 | 0.273 | ND |
| HT | G | Across from Elevator | Drinking Fountain | 8/17/2017 | ND | ND |
| HT | 1 | Pool Deck | Drinking Fountain | 8/17/2017 | 0.095 | 2.0 |
| HT | 2 | West of Room 215 | Drinking Fountain | 8/17/2017 | 0.082 | ND |
| HT | 3 | Radiology Room 312 | Sink | 8/17/2017 | 0.159 | 23.0 |
| HP | 1 | Women's Rest Room/Custodial | Sink | 8/17/2017 | 0.096 | 23.0 |
| HP | 2 | Gender Neutral Restroom | Sink | 8/17/2017 | 0.452 | 6.0 |
| LIB | 1 | Across from Room 111 | Sink | 8/17/2017 | 0.492 | 2.0 |
| LIB | 2 | Room 217 Hallway | Drinking Fountain (tall) | 8/17/2017 | 0.168 | ND |
| PAC | 1 | Room 106 Hallway | Drinking Fountain | 8/17/2017 | 0.292 | ND |
| ST | 2 | Room 200 Kitchenette | Sink | 8/17/2017 | 0.482 | ND |
| ST | 3 | Room 312C Kitchenette | Sink | 8/17/2017 | 0.421 | 6.0 |
| SS | 2 | Room 201R Kitchen | Sink | 8/17/2017 | 0.581 | 6.0 |
| TCB | 1 | Women's Rest Room | Sink | 8/17/2017 | 0.222 | 3.0 |
| TCB | 2 | Gender Neutral Restroom | Sink | 8/17/2017 | 0.194 | ND |
| TCB | 3 | Near Elevator | Drinking Fountain (low) | 8/17/2017 | 0.216 | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that there were two (2) water samples collected contained lead at concentrations that were above the EPA action level of 20 ppb. These were; SY HP Women's Rest Room sink @ 23 ppb, and SY HT 312 sink @ 23 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)



Environmental Health & Safety
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Cascade Campus

| Building | Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|---------------|-------|-------------------------------|--------------------------|-------------|-----------------------|-------------------|
| CH | 1 | Across from Room 109 | Bottle Fill Station | 8/24/2017 | 0.426 | ND |
| CH | 2 | Men's Restroom | Sink | 8/24/2017 | 0.634 | ND |
| CH | 3 | Across from Room 309 | Bottle Fill Station | 8/24/2017 | 0.260 | ND |
| JH | 1 | Between Rest Rooms / Atrium | Bottle Fill Station | 8/24/2017 | 0.099 | ND |
| JH | 2 | Across from Room 217 | Drinking Fountain (low) | 8/24/2017 | 0.321 | ND |
| LIB | 1 | Between Rest Rooms / C1-01 | Drinking Fountain (low) | 8/24/2017 | 0.210 | ND |
| LIB | 2 | Gender Neutral Rest Room | Sink | 8/24/2017 | 0.164 | ND |
| LIB | 3 | Women's Rest Room | Sink (right) | 8/24/2017 | 0.410 | ND |
| MAHB | 1 | Women's Rest Room | Sink (left) | 8/24/2017 | 0.244 | ND |
| MAHB | 2 | Men's Rest Room | Sink (right) | 8/24/2017 | 0.178 | ND |
| Paragon | 1 | Work Sink (right) | Sink | 8/24/2017 | 0.182 | 4.0 |
| PEB | 1 | Next to Room 106 / Atrium | Bottle Fill Station | 8/24/2017 | 0.269 | ND |
| PEB | 2 | Men's Rest Room | Sink (right) | 8/24/2017 | 0.293 | 5.0 |
| Public Safety | 1 | Kitchen | Sink | 8/24/2017 | ND | ND |
| PSEB | 1 | Rest Room (right) / 114A | Sink | 8/24/2017 | 0.185 | 5.0 |
| SSB | 1 | Across From Room 101 / Atrium | Bottle Fill Station | 8/24/2017 | 0.156 | 1.8 |
| SSB | 2 | Women's Rest Room | Sink (left) | 8/24/2017 | 0.204 | ND |
| SSB | 3 | Room 331 | Sink | 8/24/2017 | 0.293 | ND |
| SU | 1 | Between Rest Rooms / 107 | Bottle Fill Station | 8/24/2017 | 0.077 | ND |
| SU | 2 | Across from Elevator | Drinking Fountain (high) | 8/24/2017 | 0.540 | ND |
| SU | 3 | Room 308 | Sink | 8/24/2017 | 0.496 | ND |
| TEB | 1 | Men's Rest Room | Sink (left) | 8/24/2017 | 0.121 | ND |
| TEB | 3 | Women's Rest Room | Sink (right) | 8/24/2017 | 0.137 | ND |
| TH | 1 | Men's Rest Room | Sink (left) | 8/24/2017 | ND | ND |
| TH | 2 | Women's Rest Room | Sink (right) | 8/24/2017 | 0.068 | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)



Environmental Health & Safety
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

CLIMB Center

| Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|-------|------------------|---------------------|-------------|-----------------------|-------------------|
| 1 | Room 101 | Kitchen Sink | 8/17/2017 | 0.524 | 7.0 |
| 2 | Room 204 | Sink | 8/17/2017 | 0.358 | ND |
| 3 | Outside Room 307 | Bottle Fill Station | 8/17/2017 | 0.107 | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)



Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Willow Creek Center

| Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|-------|------------------------|--------------------------|-------------|-----------------------|-------------------|
| 1 | Room 101K Kitchen Sink | Sink | 8/24/2017 | 0.302 | ND |
| 2 | Women's Rest Room | Sink | 8/24/2017 | 0.250 | ND |
| 3 | Rest Room Fountains | Drinking Fountain (Tall) | 8/24/2017 | 0.339 | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)



Environmental Health & Safety
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Downtown Center

| Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|-------|------------------------------|------------------------------|-------------|-----------------------|-------------------|
| B | East Gender Neutral Restroom | Sink | 8/17/2017 | 0.388 | ND |
| 1 | Room 109 | Sink | 8/17/2017 | 0.156 | ND |
| 2 | Breakroom 208 | Refrigerator Water Dispenser | 8/17/2017 | 0.168 | ND |
| 3 | Men's Restroom | Sink | 8/17/2017 | 0.277 | ND |
| 4 | Breakroom 409 | Refrigerator Water Dispenser | 8/17/2017 | ND | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)



Environmental Health & Safety
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Southeast Campus

| Building | Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|-----------------|-------|--------------------------|---------------------------|-------------|-----------------------|-------------------|
| Admin | 1 | Hallway Tall Bottle Fill | Drinking Fountain | 8/17/2017 | 0.215 | ND |
| Admin | 2 | Room 202 Restroom | Sink | 8/17/2017 | 0.111 | ND |
| Admin | 3 | Room 309 Break Area | Sink | 8/17/2017 | 0.310 | ND |
| Admin | 4 | Room 403 | Sink | 8/17/2017 | 0.144 | ND |
| Annex | 1 | Room 139 Kitchen Prep | Sink | 8/17/2017 | 0.201 | ND |
| Library | 1 | Room 102 Bottle Fill | Drinking Fountain | 8/17/2017 | 0.172 | ND |
| Library | 2 | Women's Rest Room | Sink | 8/17/2017 | 0.129 | ND |
| Library | 3 | All Gender Rest Room | Sink | 8/17/2017 | 0.205 | ND |
| Mt. Scott Hall | 1 | Women's Rest Room | Sink | 8/17/2017 | 0.174 | 4.0 |
| Mt. Scott Hall | 2 | Men's Rest Room | Sink | 8/17/2017 | 0.089 | 2.0 |
| Mt. Tabor Hall | 1 | All Gender Rest Room | Sink | 8/17/2017 | 0.216 | 4.0 |
| Student Commons | 1 | Room 116Q Break Room | Sink | 8/17/2017 | 0.327 | ND |
| Student Commons | 2 | South Hall Near Room 234 | Drinking Fountain (tall) | 8/17/2017 | 0.183 | ND |
| Student Commons | 3 | North Hall Near Room 314 | Drinking Fountain (short) | 8/17/2017 | 0.164 | ND |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)



Environmental Health & Safety
District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

| Building | Level | Location | Source Type | Sample Date | Copper Results (mg/L) | Lead Result (ppb) |
|-----------|-------|--------------------------|--------------------------|-------------|-----------------------|-------------------|
| 1 | 1 | Women's Rest Room | Sink (left) | 8/24/2017 | 0.303 | ND |
| 2 | 1 | Between Rest Rooms / 115 | Drinking Fountain (tall) | 8/24/2017 | 0.144 | ND |
| 2 | 2 | Outside Room 255E | Drinking Fountain | 8/24/2017 | ND | ND |
| 3 | 1 | Across from Room 126 | Drinking Fountain (low) | 8/24/2017 | 0.051 | ND |
| 3 | 2 | Room 203 Kitchenette | Sink | 8/24/2017 | ND | ND |
| 4 | 1 | Room 102 Kitchenette | Eye-Wash / Sink | 8/24/2017 | 0.100 | 6.0 |
| 5 | 1 | Between Rest Rooms | Bottle Fill Station | 8/24/2017 | ND | ND |
| 5 | 2 | Room 264 Kitchenette | Sink | 8/24/2017 | 0.286 | ND |
| 6 | 1 | N. Hanger Rest Rooms | Drinking Fountain (low) | 8/24/2017 | 0.067 | ND |
| 7 | 1 | Across From Room 116 | Bottle Fill Station | 8/24/2017 | 0.147 | ND |
| 7 | 2 | Room 218A Kitchenette | Sink | 8/24/2017 | 0.345 | 5.0 |
| 9 | 1 | Room 114 Kitchenette | Sink | 8/24/2017 | 0.181 | ND |
| 9 | 2 | Room 212 Kitchenette | Sink | 8/24/2017 | 0.224 | ND |
| Farmhouse | | Under Reconstruction | N/A | N/A | N/A | N/A |
| Grounds | | Shop Breakroom | Sink | 8/24/2017 | 0.068 | ND |
| Farm Shop | | Main Shop | Sink | 8/24/2017 | 0.170 | ND |
| Kennel | 1 | Kennel Triple Sink | Center Sink | 8/24/2017 | 0.140 | 4.0 |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)