



**Environmental Health & Safety**  
**District Water Quality Sampling**

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Cascade Campus**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
CH	1	Room 102	Sink	8/23/2018	ND
CH	2	Women’s restroom	Sink on the right	8/23/2018	ND
CH	3	Women’s restroom	Sink on the right	8/23/2018	ND
JH	1	Lactation room	Sink	8/23/2018	5
JH	2	Women’s restroom	Sink in the middle	8/23/2018	ND
LIB	1	All gender restroom	Sink	8/23/2018	ND
LIB	2	Beside restroom and east stairwell	Drinking fountain on the right	8/23/2018	ND
LIB	3	Men’s restroom	Sink on the left	8/23/2018	2
MAHB	1	Men’s restroom	Sink on the left	8/23/2018	ND
MAHB	2	Women’s restroom	Sink on the right	8/23/2018	ND
Paragon	1	All gender restroom on the left	Sink	8/23/2018	ND
PEB	1	All gender restroom	Sink	8/23/2018	ND
PEB	2	Women’s restroom	Sink on the right	8/23/2018	ND
Public Safety	1	Room 104 kitchen	Sink	8/23/2018	ND
PSEB	1	Room 114 break room	Sink	8/23/2018	ND
SSB	1	Men’s restroom	Sink on the left	8/23/2018	ND
SSB	2	Men’s restroom	Sink on the left	8/23/2018	ND
SSB	3	All gender restroom	Sink	8/23/2018	ND
SU	1	Dining services food prep area	Sink left of the service area	8/23/2018	ND
SU	2	All gender restroom near elevator	Sink on the right	8/23/2018	ND
SU	3	Room 301 break room	Sink	8/23/2018	ND
TEB	1	Women’s restroom	Sink in the middle	8/23/2018	ND
TEB	2	Men’s restroom	Sink in the middle	8/23/2018	ND
TH	1	Women’s restroom	Sink on the left	8/23/2018	ND
TH	2	Men’s restroom	Sink on the right	8/23/2018	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)  
 ND = Non-Detect