

TESTING METHODS
Sample Type: First Draw
Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
AM	1	All gender restroom	Sink	8/21/2018	4
AM	2	North restroom tower	Drinking fountain	8/21/2018	ND
BK	G	Next to elevator	Drinking fountain on the right	8/21/2018	ND
BK	1	Women's restroom	Sink on the right	8/21/2018	4
BK	2	Next to elevator	Drinking fountain on the right	8/21/2018	ND
CC	1	Room 116E Print Center	Sink	8/21/2018	ND
CC	1	All gender restroom	Sink	8/21/2018	ND
CC	2	Left of 201A	Drinking fountain on the right	8/21/2018	ND
CC	2	Dining services food prep area	Sink closest to the clock	8/21/2018	ND
CC	2	River City Cafe - front counter	Sink	8/21/2018	2
CC	2	River City Cafe - food prep area	Sink near telephone	8/21/2018	20
CC	2	River City Cafe - food prep area	Sink near first aid kit - right faucet	8/21/2018	10
CC	2	ASPCC break room 221D	Sink	8/21/2018	4
CC	2	Veterans Resource Center break area	Sink	8/21/2018	ND
CC	2	Queer Resource Center break area	Sink	8/21/2018	ND
CSB	1	All gender restroom	Sink	8/21/2018	2
CSB	2	All gender restroom	Sink	8/21/2018	ND
CSB	3	Room 305 break room	Sink	8/21/2018	ND
CT	1	Room 126 break area	Sink	8/21/2018	15
CT	2	Room 213	Sink - left faucet	8/21/2018	8
HP	1	Custodial break room	Sink	8/21/2018	4
HP	2	All Gender Restroom	Sink	8/21/2018	6
HT	G	Room 02 weight room	Drinking Fountain	8/21/2018	ND
HT	1	Men's restroom beside Room 126	Sink in the middle	8/21/2018	ND
HT	2	Child Development Center	Results on another page	-	-
HT	3	Biology break room	Sink	8/21/2018	ND
LIB	1	All gender restroom	Sink on the left	8/21/2018	ND
LIB	2	Women's restroom	Sink on the right	8/21/2018	ND
PAC	1	Room 106 break room	Sink	8/21/2018	3
SCB	1	Restroom tower	Drinking fountain	8/21/2018	ND
SCB	2	Restroom tower	Sink in the middle	8/21/2018	ND
SS	2	Men's restroom	Sink	8/21/2018	ND
ST	2	All gender restroom	Sink	8/21/2018	ND
ST	3	Room 312C break room	Sink	8/21/2018	ND
TCB	1	Beside the elevator	Bottle fill station	8/21/2018	ND
TCB	2	Men's restroom	Sink in the middle	8/21/2018	ND
TCB	3	Room 322 breakroom	Sink	8/21/2018	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that one water sample collected contained lead at concentrations that meets the EPA action level of 20 ppb. This was River City Café – food prep area, the sink near the telephone.

River City Café is currently not open or serving food. An SRC request has been placed to have a filter installed for that location. Retesting of water source will occur once filter has been installed.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)
ND = Non-Detect