



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
7	1	Across from Room 114	Right Drinking Fountain	6/30/2020	2.3
7	1	Across from Room 116	Bottle Fill Station	6/30/2020	0.900
7	1	Men's Restroom near Room 138	Left Sink	6/30/2020	31.5
7	1	Men's Restroom near Room 114	Second Sink from Left	6/30/2020	6.00
7	1	Women's Restroom near Room 117	Second Sink from Left	6/30/2020	6.98
7	1	Room 119 Break Room	Sink	6/30/2020	1.33
7	2	Across from Room 216	Right Drinking Fountain	6/30/2020	11.9
7	2	Women's Restroom near 214	Second Sink from Right	6/30/2020	14.5
7	2	Room 202 Break Room	Sink	6/30/2020	10.2

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that one (1) water sample collected contained lead at concentrations that was above the EPA action level of 20 ppb. This was: Building 7 1st floor Men's Restroom near Room 138 sink at 31.5 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)