



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Rock Creek Campus**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	1	Room 112 Break Room	Sink	1/15/21	0.331
5	1	Outside Restrooms	Bottle Fill Station	1/15/21	ND
6	1	Women's Restroom	Sink	1/15/21	0.539
6	1	Men's Restroom	Sink	1/15/21	1.34
6	1	Outside Room 110	Bottle Fill Station	1/15/21	ND
Grounds	1	Break Room	Sink	1/15/21	1.24

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that no water samples collected contained lead at concentrations that were above the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)