



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Cascade Campus**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
LIB	1	Outside Restrooms	Bottle Fill Station	8/11/2021	ND
LIB	1	Women’s Restroom	Sink	8/11/2021	1.13
LIB	1	Room 120 Break area	Sink	8/11/2021	0.644
MAHB	1	Women’s Restroom	Sink	8/11/2021	5.15
MAHB	1	Outside Bookstore	Drinking Fountain	8/11/2021	1.21
MAHB	1	Room 105 Break area	Sink	8/11/2021	4.02
MAHB	2	Men’s Restroom	Sink	8/11/2021	2.46
MAHB	2	Outside Room 220	Drinking Fountain	8/11/2021	1.33
Paragon	1	Right Restroom	Sink	8/11/2021	0.216
SSB	1	Men’s Restroom	Sink	8/11/2021	12.9
SSB	1	Outside Restrooms	Bottle Fill Station	8/11/2021	0.906
SSB	1	Room 103 Break area	Sink	8/11/2021	4.46
SSB	2	Women’s Restroom	Sink	8/11/2021	8.51
SU	1	Outside Restrooms	Bottle Fill Station	8/11/2021	ND
SU	2	Women’s Restroom	Sink	8/11/2021	0.876
SU	2	Room 206 Break area	Sink	8/11/2021	0.800
TEB	1	Room 102 Break Room	Sink	8/11/2021	1.65
TEB	1	Women’s Restroom	Sink	8/11/2021	1.01
TEB	1	Outside Elevator	Bottle Fill Station	8/11/2021	ND
TEB	2	Men’s Restroom	Sink	8/11/2021	0.589
TEB	2	Outside Elevator	Bottle Fill Station	8/11/2021	0.239
TH	1	Women’s Restroom	Sink	8/11/2021	5.40
TH	2	Men’s Restroom	Sink	8/11/2021	2.60
TH	2	Room 220B Break area	Sink	8/11/2021	9.17

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that all water samples collected contained lead at concentrations below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)  
ND = none detected