

Environmental Health & Safety

District Water Quality Sampling

Testing Method: EPA 200.8

TESTING METHODS Sample Type: First Draw

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Cascade Campus

| Building | Level | Location | Source Type | Sample Date | Lead Result (ppb) |
|----------|-------|-------------------------|---------------------|----------------|-------------------|
| CH | 1 | Women's Restroom | Middle Sink | 5/12/2021 | 1.43 |
| СН | 1 | Men's Restroom | Middle Sink | 5/12/2021 | 1.24 |
| CH | 1 | Room 102 | Sink | 5/12/2021 | 0.767 |
| CH | 1 | Outside Restrooms | Bottle Fill Station | 5/12/2021 | ND |
| СН | 1 | Room 110 | Sink | 5/12/2021 | 6.96 |
| СН | 2 | Women's Restroom | Left Sink | 5/12/2021 | 2.27 |
| СН | 2 | Men's Restroom | Right Sink | 5/12/2021 | 1.53 |
| СН | 2 | Outside Restrooms | Bottle Fill Station | 5/12/2021 | ND |
| СН | 2 | Gender Neutral Restroom | Sink | 5/12/2021 | 1.04 |
| СН | 3 | Women's Restroom | Left Sink | 5/12/2021 | 1.46 |
| СН | 3 | Men's Restroom | Right Sink | 5/12/2021 | 0.787 |
| СН | 3 | Outside Restrooms | Bottle Fill Station | 5/12/2021 | ND |
| СН | 3 | Room 306 | Sink | 5/12/2021 | 4.84 |
| JН | 2 | Room 208 Break Room | Sink | 5/12/2021 | 3.59 |
| PEB | 1 | Women's Restroom | Middle Sink | 5/12/2021 | 3.73 |
| PEB | 1 | Men's Restroom | Middle Sink | 5/12/2021 | 6.39 |
| PEB | 1 | Outside Restrooms | Bottle Fill Station | 5/12/2021 | 0.312 |
| PEB | 2 | Women's Restroom | Right Sink | 5/12/2021 | 6.39 |
| PEB | 2 | Men's Restroom | Left Sink | 5/12/2021 | 2.65 |
| PSEB | 1 | Outside Restrooms | Bottle Fill Station | 5/12/2021 | 0.367 |
| PSEB | 1 | Break/Vending Area | Sink | 5/12/2021 | 1.84 |
| PSEB | 1 | Room 114 | Sink | 5/12/2021 | 1.73 |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document titled: 3Ts for Reducing Lead in Drinking Water in Schools.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L) ND = none detected