



## Environmental Health & Safety District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

### Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
2	1	Women's Restroom near Room	Sink	8/17/2021	31.2
3	1	Near Room 103	Bottle Fill Station	8/17/2021	ND
3	1	Men's Restroom near Auditorium	Sink	8/17/2021	5.71
3	2	Women's Restroom	Sink	8/17/2021	0.948
5	1	Women's Restroom	Sink	8/17/2021	0.216
5	1	Dining Services – Coffee Shop	Sink near Brewer	8/17/2021	3.86
5	2	Men's Restroom	Sink	8/17/2021	1.06
5	2	Outside Restrooms	Bottle Fill Station	8/17/2021	ND
5	2	Room 264 Break area	Sink	8/17/2021	ND
7	2	Women's Restroom near 236	Sink	8/17/2021	22.9
9	1	Outside Restrooms	Bottle Fill Station	8/17/2021	0.666
9	1	Women's Restroom	Sink	8/17/2021	3.31
9	2	Outside Restrooms	Bottle Fill Station	8/17/2021	0.326
9	2	Men's Restroom	Sink	8/17/2021	5.69
9	2	Room 212 Break area	Sink	8/17/2021	7.98

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that one (2) water sample collected contained lead at concentrations that were above the EPA action level of 20 ppb. This was: Building 2 1<sup>st</sup> floor Women's Restroom near Room 104 sink at 31.2 ppb and Building 7 2<sup>nd</sup> floor Women's Restroom near Room 236 sink at 22.9 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)