



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
2	1	Men's Restroom near Room 104	Right Sink	5/13/2021	9.4
2	1	Women's Restroom near Room 104	Right Sink	5/13/2021	19.7
2	2	Room 230 Break Room	Sink	5/13/2021	11.9
4	1	Women's Restroom	Sink	5/13/2021	0.811
4	1	Men's Restroom	Sink	5/13/2021	0.599
4	1	Room 102	Sink	5/13/2021	8.91
7	2	Women's Restroom near Room 236	Right Sink	5/13/2021	16.2

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document titled: *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)