



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
CT	1	Women’s Restroom	Sink	8/10/2021	1.13
CT	2	Women’s Restroom	Sink	8/10/2021	2.38
CT	2	Room 216 Break area	Sink	8/10/2021	0.87
CC	1	All User Restroom near Room 111	Sink	8/10/2021	2.23
CC	1	Women’s Restroom	Sink	8/10/2021	5.7
CC	2	Near Room 201	Drinking Fountain	8/10/2021	1.14
CC	2	Women’s Restroom near Dining Services	Sink	8/10/2021	3.71
CC	2	Near Dining Services	Bottle Fill Station	8/10/2021	1.58
CC	2	River City Café – Front Counter	Sink	8/10/2021	3.46
CC	2	ASPCC Break area	Sink	8/10/2021	1.29
LIB	1	Room 109 Break area	Sink	8/10/2021	1.55
LIB	1	Men’s Restroom	Sink	8/10/2021	2.03
LIB	1	Near Restrooms	Bottle Fill Station	8/10/2021	2.57
TCB	1	Room 115C Break area	Sink	8/10/2021	21.1
TCB	1	Outside Elevator	Bottle Fill Station	8/10/2021	4.58
TCB	2	Men’s Restroom	Sink	8/10/2021	4.08
TCB	2	Outside Elevator	Bottle Fill Station	8/10/2021	5.19
TCB	3	Women’s Restroom	Sink	8/10/2021	3.43
TCB	3	Outside Elevator	Bottle Fill Station	8/10/2021	1.40

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicated that one (1) water sample collected contained lead at concentrations that was above the EPA action level of 20 ppb. This was: TCB 1st floor Room 115C Break area sink at 21.1 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)