



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Sylvania Campus**

Building	Level	Location	Source Type	Sample Date	Copper Results (mg/L)	Lead Result (ppb)
AM	1	Room 101 Gender Neutral Restroom	Sink	6/4/2019	0.527	0.596
AM	2	Room 206	Bottle Fill Station	6/4/2019	0.0787	1.32
BK	G	Gender Neutral Restroom	Sink	6/4/2019	0.665	5.11
BK	1	Men’s Restroom	Sink	6/4/2019	0.159	1.24
BK	2	Next to Elevator	Drinking Fountain (North)	6/4/2019	0.850	0.972
CC	1	Outside Room 103	Drinking Fountain	6/4/2019	0.0904	2.47
CC	2	Room 201 Breakroom	Sink	6/4/2019	0.127	0.590
CC	2	Dining Services – Chill	Sink	6/4/2019	0.190	ND
CSB	1	Men’s Locker Room	Sink	6/4/2019	0.146	0.678
CSB	2	Room 207 Drinking Fountain	Bottle Fill Spigot	6/4/2019	0.0118	0.223
CSB	3	Between Restrooms	Drinking Fountain (East)	6/4/2019	0.498	0.365
CT	1	Room 126 Child Development	Sink	6/4/2019	0.103	8.46
CT	2	Room 216 Break Room	Sink	6/4/2019	0.312	ND
HP	1	Men’s Restroom	Sink (Right)	6/4/2019	0.232	2.20
HP	2	Gender Neutral Restroom	Sink	6/4/2019	0.542	3.07
HT	G	Room 05 Break Room	Sink	6/4/2019	0.115	0.272
HT	1	Room 122 Break Room	Sink	6/4/2019	0.520	0.322
HT	2	Room 222 Kitchenette	Sink (South)	6/4/2019	0.197	0.878
HT	2	Room 204	Sink	6/4/2019	0.184	4.48
HT	3	Men’s Restroom	Sink (Right)	6/4/2019	0.227	1.59
LIB	1	Men’s Restroom	Sink (Second from Left)	6/4/2019	0.112	1.72
LIB	2	Men’s Restroom	Sink (Left)	6/4/2019	0.118	1.67
PAC	1	Men’s Restroom (near Dressing Room)	Sink (Left)	6/4/2019	0.0571	2.25
SS	2	Women’s Restroom	Sink	6/4/2019	0.218	1.31
ST	2	Near Room 206	Drinking Fountain	6/4/2019	0.0950	ND
ST	3	Men’s Restroom (North Bunker)	Sink (Right)	6/4/2019	0.287	ND
TCB	1	Men’s Restroom	Sink	6/4/2019	0.115	1.85
TCB	2	Women’s Restroom	Sink (Left)	6/4/2019	0.122	1.24
TCB	3	Lactation Room	Sink	6/4/2019	0.691	15.3

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

Laboratory analysis indicates that all water samples collected contained copper at concentrations that were below the EPA action level of 1.3 mg/L.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)  
mg/L = milligrams per liter (i.e., 0.020 mg/L = 20 ppb)