

## Confined Space Entry & Tunnel Safety – Appendix C: Confined Space Index – PMWTC Center / Opportunity Center at 42nd Ave

The following table provides index and initial space classification for spaces at PMWTC - Metro / Opportunity Center at 42nd Ave (OC42). The numbers noted are related to notation on maps.

Map Location #	Building/Location	Space Type or Name / Conditions	Classification	
<b>100 - Vault with Single / Double and Triple Square Covers</b>				
Outside locations throughout the campus includes: <b>Backflow Preventer Vaults, FDC valves and electrical vaults</b>				
101	Parking Lot	Stormwater Management system vault – <b>TOO SHALLOW TO ENTER</b>	<i>not a confined space</i>	
102	Sidewalk on 42nd Street North end of the campus parking lot.	Potable Water Vault for Fire and Drinking Water valves and backflow assembly.	<b>Permit-Required Confined Space</b>	<ul style="list-style-type: none"> <li>• Atmospheric hazards</li> <li>• Water flow – engulfment.</li> <li>• Possible physical hazards</li> </ul>
103	Sidewalk on Killingsworth Street North at main entrance – west side of the driveway.	Vault hatch cover – water meter, less than 1 foot deep – <b>TOO SHALLOW TO ENTER</b>	<i>not a confined space</i>	
104	Sidewalk on Killingsworth Street North at main entrance – east side of the driveway.	Vault hatch cover – Water meter piping. <b>TOO SHALLOW TO ENTER</b>	<i>not a confined space</i>	
Sewer manholes are the responsibility of the local City of Portland Environmental Services.				
<b>200 - HVAC</b>				
201	HVAC plenum/filter housing	Roof units Lockout and fall protection required	<i>not a confined space</i>	
<b>Boiler Systems</b>				
NEW boilers are NOT confined spaces & cannot be entered. Ductwork is also too small to enter.				
<b>300 - Tanks</b>				
	None			