

Confined Space Entry & Tunnel Safety – Appendix C: Confined Space Index – PMWTC Center

The following table provides index and initial space classification for spaces at PMWTC - Metro. The numbers noted are related to notation on maps.

Map Location #	Building/Location	Space Type or Name / Conditions	Classification
100 - Vault with Single / Double and Triple Square Covers			
Outside locations throughout the campus includes: Backflow Preventer Vaults, FDC valves and electrical vaults			
101	Parking Lot	Stormwater Management system vault – TOO SHALLOW TO ENTER	NOT a confined space
102	Sidewalk on 42nd Street North end of the campus parking lot.	Potable Water Vault for Fire and Drinking Water valves and backflow assembly.	PERMIT / ALTERNATIVE
103	Sidewalk on Killingsworth Street North at main entrance – west side of the driveway.	Vault hatch cover – water meter, less than 1 foot deep – TOO SHALLOW TO ENTER	NOT a confined space.
104	Sidewalk on Killingsworth Street North at main entrance – east side of the driveway.	Vault hatch cover – Water meter piping. TOO SHALLOW TO ENTER	NOT a confined space.
Sewer manholes are responsibility of the local City of Portland Environmental Services.			
200 - HVAC			
201	HVAC plenum/filter housing	Roof units	NOT confined spaces. Lockout and fall protection REQUIRED
Boiler Systems			
NEW boilers are NOT confined spaces & cannot be entered. Ductwork is also too small to enter.			
300 - Tanks			
	None		

Confined Space Entry & Tunnel Safety – Appendix C: Confined Space Index – PMWTC Center

PCC Confined Space Location Maps Portland Metropolitan Workforce Training Center

5600 NE 42nd Avenue
Portland, Oregon
June 2015

