

Confined Space Entry & Tunnel Safety – Appendix C: Confined Space Index – Newberg Center






The following table provides index and initial space classification for spaces at Newberg Center.
The numbers noted are related to notation on maps.

| Map Location # | Building/Location | Space Type or Name / Conditions | Classification | Hazards |
|--|--|--|---------------------------------------|---|
| 100 - Vault with Single / Double and Triple Square Covers | | | | |
| Outside locations throughout the campus includes: Backflow Preventer Vaults, FDC valves and electrical vaults | | | | |
| 101 | Vault corner of Brutshcer and Werth Blvd. near N102 | Water vault with large water supply pipe and valve. Standing water, at least 8 feet deep with a stationary ladder for access. | Permit-Required Confined Space | <ul style="list-style-type: none"> ● Atmospheric hazards ● Falling or slipping ● High pressure water lines – physical pressure and drowning |
| 102 | Corner of Brutshcer and Werth Blvd. | PGE Electric vault at least 5 feet deep with electrical cables | Permit-Required Confined Space | <ul style="list-style-type: none"> ● Electrical hazards ● Falls |
| 103 | Triple lid vault after the circle turn around before the service drive that goes behind the building | Electrical Vault | Permit-Required Confined Space | <ul style="list-style-type: none"> ● Electrical hazards ● Falls |
| 104 | Vault on the sidewalk on Brutshcer street at the edge of the property | To be determined | Permit-Required Confined Space | <ul style="list-style-type: none"> ● Possible atmospheric hazards ● Water flow – engulfment. ● Possible physical hazards from falling or slipping. |
| NO storm water manholes as bio-swale controls storm water. | | | | |
| Sewer manholes are the responsibility of the local City of Newberg Environmental Services. | | | | |
| 200 - HVAC | | | | |
| 201 | HVAC plenum/filter housing | The issues fall hazard which has been addressed with proper anchor points Lockout and fall protection on HRV#1-3 filter access points | <i>not a confined space</i> | |
| 300 - Tanks | | | | |
| | None | | | |

PCC Confined Space Location Maps

Newberg Center

135 Werth Blvd
Newberg, Oregon
June 2015

| LEGEND | |
|---|------------------------|
|  | CONFINED SPACE |
|  | GRASS/GRAVEL LANDSCAPE |
|  | BIO-SWALE |
|  | PAVED |
|  | SIDEWALK |

