Confined Space Entry & Tunnel Safety – Appendix C: Confined Space Index – Swan Island Center

The following table provides index and initial space classification for spaces at Swan Island Center. The numbers noted are related to notation on maps.

Map Location #	Building/Location	Space Type or Name / Conditions	Classification	Hazards
	th Single / Double and Triple Square Covers	renter Verilte, FDC values and a	No otrical varilta	
100	Ons throughout the campus includes: Backflow Prev Outside STC Corner of Cutter and Leverman Streets.	Double hatch Quest Communication vault with wiring system relatively shallow at about 2 feet.	not a confined space	
101	Vault near gas pumps.	Single hatch, deep, full of water, some conduit at bottom of the vault.	Permit-Required Confined Space	 Electrical hazards Falls
102	Exit on Cutter Street. In the sidewalk (blue markings).	City of Portland Water Vault may be responsibilities by PCC for backflow preventer testing.	Permit-Required Confined Space	 Atmospheric hazards in the space Falling or slipping High pressure water lines – engulfment
103	Vault in North Parking Lot at sign Row 8	No ladder, water in access to water line and valve/meter.	Permit-Required Confined Space	 Atmospheric hazards in the space Falling or slipping High pressure water lines – engulfment
104	Raised water vault off sidewalk near Cutter and Leverman Streets.	Vault appears 8 feet by 6 feet, no sure on depth but generally these are 6 to 8 feet deep.	not a confined space	
NO storm water	NO storm water manholes as bio-swale controls storm water.			
Sewer manholes are responsibility of the local City of Portland Environmental Services.				

