

Compressed Gas Safety Plan – Form 1: Inspection Checklist

Department: _____ Date: _____

Location: _____

Inspection Completed by: _____

Description	Yes	No	N/A	Comments
Emergency Preparedness				
• Emergency Guide posted				
• Fire Extinguishers mounted, accessible, inspected				
• First aid kits available nearby and well stocked				
• Spill kits present and with appropriate material				
• Fire blankets accessible				
• Emergency map with evacuation routes posted				
• Leak detection equipment is working properly				
Equipment				
• Cylinders are not dented, corroded, or otherwise damaged				
• Labels/markings are intact and legible				
• Hoses and fittings are not dented, bulging, or otherwise damaged				
• Regulators and valves are clean and working properly				
• Appropriate personal protective equipment available in sufficient quantities and in good condition				
Storage				
• Cylinders are securely strapped or chained to prevent falling				
• When not in use, regulators are disconnected, and valve caps are securely in place				
• Emergency equipment isn't blocked				
• Cylinders are stored away from localized heat sources				
• Material handling equipment for moving tanks is available and not damaged				
• Proper separation is maintained between incompatible gases				
• Empty and full cylinders are stored separately				
Other Issues Noted:				