



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
AM	1	Room 103	Sink	6/15/22	3.03
AM	2	Outside Room 206	Bottle Fill Station	6/15/22	1.37
BK	G	Outside Elevator	Drinking Fountain	6/15/22	ND
BK	1	Room 108A Breakroom	Sink	6/15/22	0.875
BK	2	Outside Elevator	Drinking Fountain	6/15/22	0.688
CC	1	Gender Neutral Restroom	Sink	6/15/22	2.11
CC	2	Room 214E Breakroom	Sink	6/15/22	ND
CC	2	Dining Services – River City	Prep Sink	6/15/22	1.37
CSB	1	Room 109	Sink	6/15/22	0.404
CSB	2	Break Area	Sink	6/15/22	0.259
CSB	3	Room 305 Breakroom	Sink	6/15/22	0.296
CT	1	Main Lobby	Bottle Fill Station	6/15/22	ND
CT	2	Room 216 Breakroom	Sink	6/15/22	0.398
HP	1	Room 106 Break Area	Sink	6/15/22	9.87
HP	2	Room 201	Sink	6/15/22	3.44
HT	G	Room 04 Breakroom	Sink	6/15/22	ND
HT	1	Women's Locker Room	Drinking Fountain	6/15/22	0.781
HT	2	Gym	Left Bottle Fill Station	6/15/22	0.257
LIB	1	Outside Restrooms	Bottle Fill Station	6/15/22	0.714
LIB	2	Outside Restrooms	Bottle Fill Station	6/15/22	0.613
MOD	1	Women's Restroom	Sink	6/15/22	1.68
PAC	1	Outside Room 106	Bottle Fill Station	6/15/22	ND
SS	2	Room 201R Breakroom	Sink	6/15/22	1.39
ST	2	Room 213K Breakroom	Sink	6/15/22	0.795
ST	3	Room 312C Breakroom	Sink	6/15/22	0.580
TCB	1	Outside Restrooms	Bottle Fill Station	6/15/22	3.10
TCB	2	Outside Restrooms	Bottle Fill Station	6/15/22	1.15
TCB	3	Room 322 Breakroom	Sink	6/15/22	1.74

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)