



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Child Development Center

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
Main	1	Room 106 Lactation	Sink	6/15/22	1.75
Main	1	Room 107	Sink	6/15/22	ND
Main	1	Room 108	Sink (Right)	6/15/22	0.504
Main	1	Room 108	Sink (Left)	6/15/22	0.810
Main	1	Room 110	Sink	6/15/22	ND
Main	1	Restroom (Right)	Sink	6/15/22	ND
Main	1	Restroom (Left)	Sink	6/15/22	ND
Main	1	Near Room 116	Bottle Fill Station	6/15/22	ND
Main	1	Laundry Room	Sink	6/15/22	ND
Main	1	Room 115 Kitchen	Sink (Right)	6/15/22	0.756
Main	1	Room 115 Kitchen	Sink (Left)	6/15/22	0.269
Main	2	Break Area	Sink	6/15/22	ND
Main	2	Gender Neutral Restroom (Left)	Sink	6/15/22	ND
Main	2	Gender Neutral Restroom (Right)	Sink	6/15/22	ND
Bldg 2	1	Room 117	Sink (Tall)	6/15/22	0.419
Bldg 2	1	Room 117	Sink (Short)	6/15/22	1.04
Bldg 2	1	Room 118	Sink	6/15/22	0.699
Bldg 2	1	Room 119	Sink – Northeast	6/15/22	0.466
Bldg 2	1	Room 119	Sink – Southeast	6/15/22	0.467
Bldg 2	1	Room 119	Sink – Southwest	6/15/22	0.666
Bldg 2	1	Room 119	Sink – Northwest	6/15/22	0.336
Bldg 2	1	Room 120	Sink (Tall)	6/15/22	0.771
Bldg 2	1	Room 120	Sink (Short)	6/15/22	7.65
Bldg 3	1	Room 121	Sink (Tall)	6/15/22	0.467
Bldg 3	1	Room 121	Sink (Short)	6/15/22	0.763
Bldg 3	1	Room 122a	Sink (Tall - South)	6/15/22	1.67
Bldg 3	1	Room 122a	Sink (Short - South)	6/15/22	0.660
Bldg 3	1	Room 122b	Sink (Tall - North)	6/15/22	0.335
Bldg 3	1	Room 122b	Sink (Short - North)	6/15/22	0.704
Bldg 3	1	Room 124	Sink (Tall)	6/15/22	0.346
Bldg 3	1	Room 124	Sink (Short)	6/15/22	1.37

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)