



**Environmental Health & Safety
District Water Quality Sampling**

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Carolyn Moore Writer's House

| Level | Location | Source Type | Sample Date | Lead Result (ppb) |
|-------|----------------------|-----------------|-------------|-------------------|
| 1 | East Kitchen (large) | Sink near Stove | 6/16/22 | 0.324 |
| 1 | West Kitchen (small) | Sink | 6/16/22 | 3.48 |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)