



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	1	Men's Restroom	Sink	6/14/23	0.324
2	1	Welding Shop	Bottle Fill Station	6/14/23	ND
2	2	Room 220 Breakroom	Sink	6/14/23	1.270
3	1	Women's Restroom	Sink	6/14/23	0.289
3	2	Women's Restroom	Sink	6/14/23	0.205
4	1	Room 102	Sink	6/14/23	3.440
5	1	Outside Locker Rooms	Bottle Fill Station	6/14/23	1.870
5	1	Dining Services Kitchen	Sink	6/14/23	0.284
5	2	Outside Restrooms	Bottle Fill Station	6/14/23	ND
6	1	Room 108 Breakroom	Sink	6/14/23	0.419
7	1	Room 119 Breakroom	Sink	6/14/23	ND
7	2	Near Room 216	Drinking Fountain	6/14/23	2.510
9	1	Room 114 Breakroom	Sink	6/14/23	0.250
9	2	Room 212 Breakroom	Sink	6/14/23	0.273
10	1	Room 101 Breakroom	Sink	6/14/23	1.240
Kennel	1	Restroom	Sink	6/14/23	0.881
Grounds	1	Breakroom	Sink	6/14/23	0.728
Farmhouse	1	Kitchen	Sink	6/14/23	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 µg/L)