



TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Campus HT East Side Renovation

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
HT	1	Near North Entrance	Bottle Fill Station	7/18/23	ND
HT	1	Room 118 Weight Lifting	Bottle Fill Station	7/18/23	ND
HT	1	South Restroom	Sink	7/18/23	0.263
HT	2	South Restroom	Sink	7/18/23	0.710
HT	2	North Gym Entrance	Bottle Fill Station	7/18/23	ND
HT	2	Room 207G Kitchen	Sink	7/18/23	0.478
HT	2	Central Restroom	Sink	7/18/23	0.616
HT	2	Outside Skills Lab	Sink	7/18/23	12.90
HT	2	South Gym Entrance	Bottle Fill Station	7/18/23	ND
HT	2	North Restroom	Sink	7/18/23	0.670
HT	3	Room 305 Lactation Room	Sink	7/18/23	0.243
HT	3	Restroom	Sink	7/18/23	1.240
HT	3	Outside Restroom	Bottle Fill Station	7/18/23	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 µg/L)