



## Environmental Health & Safety District Water Quality Sampling

### TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

### Cascade Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
CH	1	Head Start Outside Room 101G	Drinking Fountain (Short)	9/2/2016	ND
CH	2	Next to Men's Restroom	Drinking Fountain	9/2/2016	ND
CH	3	Room 306 East End	Sink	9/2/2016	ND
JH	1	Outside Room 113	Drinking Fountain	9/2/2016	ND
JH	2	Room 208	Sink	9/2/2016	1.5
LIB	1	Between Rooms 116 & 117	Kitchen Sink	9/2/2016	ND
LIB	2	Near Room 202	Drinking Fountain (Tall)	9/2/2016	ND
LIB	3	Near Elevator	Drinking Fountain (Short)	9/2/2016	ND
MCTE	1	Next to Elevator	Drinking Fountain	9/2/2016	ND
MCTE	2	Outside Room 222	Drinking Fountain (West)	9/2/2016	ND
MAHB	1	Outside Bookstore Room 100	Drinking Fountain (Tall)	9/2/2016	ND
MAHB	2	Next to Elevator Equipment Room	Drinking Fountain (Short)	9/2/2016	ND
Paragon	1	Women's Restroom	Sink	9/2/2016	1.7
PEB	1	Outside Room 109	Drinking Fountain (South)	9/2/2016	ND
PEB	2	Next to Elevator	Drinking Fountain	9/2/2016	ND
Public Safety	1	Kitchen	Sink	9/2/2016	13
PSEB	1	Across From Room 110	Drinking Fountain	9/2/2016	ND
SSB	1	Across From Room 118	Sink	9/2/2016	1.8
SSB	2	Across From Room 201	Drinking Fountain (Tall)	9/2/2016	ND
SSB	3	Between Gender Neutral Restrooms	Drinking Fountain	9/2/2016	ND
SU	1	Cafeteria Kitchen Near Pizza Oven	Sink	9/2/2016	ND
SU	2	Room 210D Break Area	Sink	9/2/2016	ND
SU	3	Next to Room 309	Drinking Fountain (Short)	9/2/2016	ND
TH	1	East of Art Display Area	Drinking Fountain	9/2/2016	ND
TH	2	Across From Room 202	Drinking Fountain	9/2/2016	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document, entitled *3Ts for Reducing Lead in Drinking Water in Schools*. First draw samples were collected and laboratory analysis indicates that all water samples collected contained lead at concentrations below the EPA action level of 20 ppb.

ppb = parts per billion (20 ppb = 0.020 mg/L)