



Environmental Health & Safety District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Rock Creek Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
1	1	Room 112 Kitchen Area	Sink	9/2/2016	ND
2	1	Room 104 Carpentry	Drinking Fountain	9/2/2016	1.1
2	2	Room 237	Sink	9/2/2016	ND
3	1	Outside Room 108	Drinking Fountain	9/2/2016	ND
3	2	Hall Outside Rooms 201-217	Drinking Fountain	9/2/2016	ND
4	1	Main Hallway	Bottle Fill Station	9/2/2016	ND
5	1	Main Cafeteria Kitchen	Sink	9/2/2016	ND
5	2	Room 241 Kitchen	Sink	9/2/2016	3.2
6	1	Outside Room 110	Drinking Fountain (Tall)	9/2/2016	ND
7	1	Across From Room 114	Drinking Fountain (Tall)	9/2/2016	ND
7	2	Room 202 Break Area	Sink	9/2/2016	2.5
9	1	Near Testing Center	Bottle Fill Station	9/2/2016	ND
9	2	Next to J21 in Library	Drinking Fountain (Tall)	9/2/2016	ND
Farmhouse	1	Kitchen	Sink	9/2/2016	3.8
Kennel	1	Main Office Room	Sink	9/2/2016	3.2

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document, entitled *3Ts for Reducing Lead in Drinking Water in Schools*. First draw samples were collected and laboratory analysis indicates that all water samples collected contained lead at concentrations below the EPA action level of 20 ppb.

ppb = parts per billion (20 ppb = 0.020 mg/L)