



Environmental Health & Safety District Water Quality

Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Southeast Campus

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
Admin	1	Hallway	Drinking Fountain	9/1/2016	ND
Admin	2	Room 207 Break Area	Sink	9/2/2016	ND
Admin	3	Room 309 Break Area	Sink	9/2/2016	ND
Admin	4	Room 410 Break Room	Sink	9/1/2016	ND
Annex	1	Room 123 Break Area	Sink	9/2/2016	ND
Library	1	Room 116 Break Area	Sink	9/1/2016	ND
Library	2	Room 224 SE Corner	Bottle Fill Station	9/1/2016	ND
Library	3	Room 301 SE Corner	Drinking Fountain (Tall)	9/1/2016	ND
Mt. Scott Hall	1	Outside Room 100	Drinking Fountain	9/1/2016	ND
Mt. Scott Hall	2	Outside Room 200	Drinking Fountain	9/1/2016	1.2
Mt. Tabor Hall	1	Cafeteria Kitchen	Sink in Food Prep Area	9/1/2016	ND
Student Commons	1	Main Hall Southside	Bottle Fill Station	9/1/2016	ND
Student Commons	2	Room 217	Sink	9/1/2016	2.6
Student Commons	3	South Hall Near Room 300	Bottle Fill Station	9/1/2016	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document, entitled *3Ts for Reducing Lead in Drinking Water in Schools*. First draw samples were collected and laboratory analysis indicates that all water samples collected contained lead at concentrations below the EPA action level of 20 ppb.

ppb = parts per billion (20 ppb = 0.020 mg/L)