



Environmental Health & Safety District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Child Development Center

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
Main	1	Room 106 Lactation	Sink	8/13/25	3.530
Main	1	Room 107	Sink	8/13/25	0.221
Main	1	Room 108	Sink (Right)	8/13/25	1.750
Main	1	Room 108	Sink (Left)	8/13/25	2.200
Main	1	Room 110	Sink	8/13/25	ND
Main	1	Restroom (Right)	Sink	8/13/25	ND
Main	1	Restroom (Left)	Sink	8/13/25	ND
Main	1	Near Room 116	Bottle Fill Station	8/13/25	ND
Main	1	Laundry Room	Sink	8/13/25	0.382
Main	1	Room 115 Kitchen	Sink (Right)	8/13/25	0.802
Main	1	Room 115 Kitchen	Sink (Left)	8/13/25	ND
Main	2	Break Area	Sink	8/13/25	ND
Main	2	Gender Neutral Restroom (Left)	Sink	8/13/25	0.333
Main	2	Gender Neutral Restroom (Right)	Sink	8/13/25	ND
Bldg 2	1	Room 117	Sink (Tall)	8/13/25	0.438
Bldg 2	1	Room 117	Sink (Short)	8/13/25	0.711
Bldg 2	1	Room 118	Sink	8/13/25	ND
Bldg 2	1	Room 119	Sink – Northeast	8/13/25	0.919
Bldg 2	1	Room 119	Sink – Southeast	8/13/25	2.640
Bldg 2	1	Room 119	Sink – Southwest	8/13/25	1.860
Bldg 2	1	Room 119	Sink – Northwest	8/13/25	4.460
Bldg 2	1	Room 120	Sink (Tall)	8/13/25	0.628
Bldg 2	1	Room 120	Sink (Short)	8/13/25	2.500
Bldg 3	1	Room 121	Sink (Tall)	8/13/25	1.410
Bldg 3	1	Room 121	Sink (Short)	8/13/25	1.110
Bldg 3	1	Room 122a	Sink (Tall - South)	8/13/25	0.222
Bldg 3	1	Room 122a	Sink (Short - South)	8/13/25	1.360
Bldg 3	1	Room 122b	Sink (Tall - North)	8/13/25	0.262
Bldg 3	1	Room 122b	Sink (Short - North)	8/13/25	1.530
Bldg 3	1	Room 124	Sink (Tall)	8/13/25	1.070
Bldg 3	1	Room 124	Sink (Short)	8/13/25	1.410

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)