



**Environmental Health & Safety**  
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

**Sylvania Child Development Center**

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
HT	1	Restroom T1-02	Sink - Left Center	2/18/26	2.660
HT	1	Collab C1-06A	Bottle Fill Station	2/18/26	ND
HT	1	Room 107	Sink	2/18/26	1.030
HT	1	Men's Locker Room	Sink	2/18/26	0.833
HT	1	Shower Area North Block ADA	Sink	2/18/26	1.940
HT	1	Shower Area Center Block ADA	Sink	2/18/26	0.840
HT	1	Shower Area South Block ADA	Sink	2/18/26	2.370
HT	1	Room 122	Sink	2/18/26	0.901
HT	1	Room 123A	Sink - Left	2/18/26	0.645
HT	1	Restroom T1-03	Sink	2/18/26	0.901
HT	1	Restroom T1-03 ADA	Sink	2/18/26	2.660
HT	1	Women's Locker Room	Sink	2/18/26	0.822
HT	1	Room 112	Sink	2/18/26	0.630
HT	2	Room 211	Sink	2/18/26	0.706
HT	2	Room 213	Sink - Left	2/18/26	1.740
HT	2	Room 213	Sink - Right	2/18/26	2.570
HT	2	Room 213B	Sink	2/18/26	1.240
HT	2	Room 214B	Sink	2/18/26	1.710
HT	2	Room 214	Sink - Right	2/18/26	1.460
HT	2	Room 214	Sink - Left	2/18/26	1.580
HT	2	Room 216	Sink	2/18/26	0.209
HT	2	Near Restroom	Bottle Fill Station	2/18/26	1.500
HT	2	Restroom T2-04	Sink - Right Center	2/18/26	3.370
HT	2	Room 266 Gym	Bottle Fill Station	2/18/26	ND

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)