



Environmental Health & Safety District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA's Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Child Development Center

Building	Level	Location	Source Type	Sample Date	Lead Result (ppb)
Main	1	Room 106 Lactation	Sink	7/15/26	2.38
Main	1	Room 107	Sink	7/15/26	0.359
Main	1	Room 108	Sink (Right)	7/15/26	2.14
Main	1	Room 108	Sink (Left)	7/15/26	2.20
Main	1	Room 110	Sink	7/15/26	ND
Main	1	Restroom (Right)	Sink	7/15/26	ND
Main	1	Restroom (Left)	Sink	7/15/26	ND
Main	1	Near Room 116	Bottle Fill Station	7/15/26	ND
Main	1	Laundry Room	Sink	7/15/26	NT
Main	1	Room 115 Kitchen	Sink (Right)	7/15/26	ND
Main	1	Room 115 Kitchen	Sink (Left)	7/15/26	1.28
Main	2	Break Area	Sink	7/15/26	ND
Main	2	Gender Neutral Restroom (Left)	Sink	7/15/26	ND
Main	2	Gender Neutral Restroom (Right)	Sink	7/15/26	ND
Bldg 2	1	Room 117	Sink (Tall)	7/15/26	0.245
Bldg 2	1	Room 117	Sink (Short)	7/15/26	0.859
Bldg 2	1	Room 118	Sink	7/15/26	ND
Bldg 2	1	Room 119	Sink – Northeast	7/15/26	1.02
Bldg 2	1	Room 119	Sink – Southeast	7/15/26	2.33
Bldg 2	1	Room 119	Sink – Southwest	7/15/26	1.74
Bldg 2	1	Room 119	Sink – Northwest	7/15/26	3.21
Bldg 2	1	Room 120	Sink (Tall)	7/15/26	0.565
Bldg 2	1	Room 120	Sink (Short)	7/15/26	1.28
Bldg 3	1	Room 121	Sink (Tall)	7/15/26	1.03
Bldg 3	1	Room 121	Sink (Short)	7/15/26	0.932
Bldg 3	1	Room 122a	Sink (Tall - South)	7/15/26	ND
Bldg 3	1	Room 122a	Sink (Short - South)	7/15/26	0.961
Bldg 3	1	Room 122b	Sink (Tall - North)	7/15/26	ND
Bldg 3	1	Room 122b	Sink (Short - North)	7/15/26	1.17
Bldg 3	1	Room 124	Sink (Tall)	7/15/26	0.923
Bldg 3	1	Room 124	Sink (Short)	7/15/26	1.47

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools*.

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 20 ppb.

ppb = parts per billion (i.e., 20 ppb = 0.020 mg/L)

Please note the laundry room was not tested.